

	Yes	No	N/A
Fire Extinguishers			
Is the travel distance to any fire extinguisher less than 75 feet?			
Have all fire extinguishers been serviced and tagged by a licensed fire extinguisher service company within the last twelve (12) months?			
Are all fire extinguishers visible, accessible, and mounted no higher than sixty (60) inches from the floor to the top of the extinguisher?			
Are fire extinguishers at least rated as a 2A-10BC minimum size/type?			
Fire suppression systems			
If the building is equipped with a fire suppression (sprinkler) system, has the required test/service been performed by a licensed contractor within the last twelve (12) months?			
Is there a minimum 18-inch clearance below sprinkler deflectors and the top of storage?			
For commercial cooking, has the hood suppression system been serviced within the last six (6) months?			
Housekeeping and storage			
Is the storage of combustible materials neat, orderly and piled no higher than two (2) feet below the ceiling?			
Are oily rags or similar materials stored in metal, metal-lined or other approved containers equipped with tight-fitting covers?			
Are equipment rooms, mechanical rooms, electrical rooms, and areas under open stairways maintained clear of combustible material storage?			
Are flammable liquids stored in approved safety cans?			
Are quantities of flammable or combustible liquids in excess of ten (10) gallons stored in approved storage cabinets?			
Are compressed gas containers (CO ₂ , helium, etc.) secured to prevent falling?			
Are portable electric heaters an approved type, plugged directly into a wall outlet and kept a minimum of three (3) feet away from combustibles?			
Are all combustibles storage at least three (3) feet away from gas fired appliances (water heaters, furnaces, etc.)?			

Note: You will be contacted by an OFD Inspector for all “No” responses to address violations. All violations must be corrected within 30 days of the inspection date. If violations are not remedied, you will be subject to a re-inspection fee of \$80 for each inspection thereafter.

1. No Misrepresentations, False Statements, Inaccurate Information. You hereby represent to the Fire Department that you provided information for the completion of your business inspection without intentionally or negligently making false statements or misrepresentations of any kind during the course of the Inspection. Further, you agree to be responsible for any damages or claims made against the Fire Department that arose from or were caused by you providing false or inaccurate information or making misrepresentations during the course of your Inspection.

2. Indemnity. You agree to indemnify and hold the Fire Department, its officers, employees and agents, harmless from any third-party claim or cause of action, including reasonable attorneys’ fees and costs, arising, directly or indirectly, out of your access to or use of Fire Department affiliated web sites, e-mails or inspection results in connection with your Inspection, the information contained therein, and the results thereof, or your violation of any law or the rights of any person.

Print Name of Person Performing the Inspection _____ Date _____

Signature of Responsible Person _____ Date _____

**Checks should be made payable to:
Oberlin Fire Department
c/o Fire Recovery USA Processing Center
2271 Lava Ridge Court, Suite 120
Roseville, CA 95661**